


# AGRO Ex cable glands nickel-plated brass for flameproof enclosure Ex d IIC



## Entry thread NPT

### Type approval: Serie 18

- One-piece sealing insert
- not overall length insulated

|                       |                                                   |
|-----------------------|---------------------------------------------------|
| <b>Article no:</b>    | <b>181NPT.21.27</b>                               |
| EAN:                  | 7611614043227                                     |
| Material              | Nickel-plated brass                               |
| Screws                | Stainless steel A2                                |
| Seal                  | NBR                                               |
| Operation temperature | -40°C / +100°C                                    |
| Protection class      | IP 68 (30 bar)                                    |
| Test standard         | IEC EN 60079-0 / IEC EN 60079-1 / IEC EN 60079-31 |
| Gas                   | II 2 G Ex db eb IIC Gb                            |
| Dust                  | II 2 D Ex ta IIIC Ga                              |
| Zone                  | Gas 1 and 2 / dust 21 and 22                      |
| Certificate           | PTB 00 ATEX 1059                                  |
| IECEx Certificate     | IECEx PTB 12.0056                                 |
| Entry thread (G)      | NPT 1"                                            |
| Clamping range min.   | 16.5 mm                                           |
| Clamping range max.   | 20.0 mm                                           |
| Wrench size           | 36 mm                                             |
| Diameter A            | 44 mm                                             |
| Dimension (H)         | 67 mm                                             |
| Thread length (L)     | 25 mm                                             |
| Dispatch              | 10                                                |

IP 68, if the entry thread is sealed